13.02.2019

14:36:53h

SCHMERSAL

Datasheet - AZ 17-02ZK

Safety switch with separate actuator / AZ 17

X Preferred typ



Thermoplastic enclosure

- Double-insulated
- Long life
- 30 mm x 60 mm x 30 mm
- Small body
- Multiple coding
- · High level of contact reliability with low voltages and currents
- Insensitive to soiling
- 8 actuating planes
- cable gland M16

(Minor differences between the printed image and the original product may exist!)

Ordering details

Product type description
Article number
EAN Code
eCl@ss

Approval

Approval





Classification

Standards B10d Normally-closed contact (NC) Mission time notice EN ISO 13849-1 2.000.000 20 Years $MTTF_{d} = \frac{B_{100}}{0.1 \times n_{op}}$

 $n_{op} = \frac{d_{op} \times h_{op} \times 3600 \text{ s/h}}{t_{oyole}}$

Global Properties

Permanent light	AZ 17
Standards	EN 60947-5-1, BG-GS-ET-15
Materials	
- Material of the housings	Plastic, glass-fibre reinforced thermoplastic, self-extinguishing
- Material of the contacts	Silver
Housing coating	None
Weight	85

Mechanical data

Design of electrical connection	IDC method of termination
Cable section	
- Min. Cable section	1 x 0,75
- Max. Cable section	1 x 1
Mechanical life	> 1.000.000 operations
higher Latching force (Y/N)	No
Latching force	5
Positive break force	17 N
positive break travel	11 mm
Max. Actuating speed	2 m/s

Ambient conditions

Protection class

IP67 to IEC/EN 60529

Electrical data

Design of control element	Opener (NC)
Switching principle	Creep circuit element
Number of auxiliary contacts	0
Number of safety contacts	2
Rated impulse withstand voltage Uimp	4 kV
Rated insulation voltage Ui	250 V
Thermal test current Ithe	10 A
Utilisation category	AC-15: 230 V / 4 A DC-13: 24 V / 4 A
Max. fuse rating	6 A gG D-fuse

ATEX

Explosion protection categories for gases	None
Explosion protected category for dusts	None

Dimensions

30	
85	
30	
	85


Individual coding available on request

This type termination (IDC) method enables simple connetion of flexible conductors without the need for the use of conductor ferrules

Included in delivery

Actuators must be ordered separately. Slot sealing plugs

Diagram



 \ominus positive break NC contact


 $\textcircled{1}_{\text{active}}$

no active

°----- Normally-open contact

o-it----o Normally-closed contact

Switch travel diagram



Documents

Operating instructions and Declaration of conformity (pl) 526 kB, 24.09.2018 Code: mrl_az17_pl

Operating instructions and Declaration of conformity (ro) 511 kB, 25.01.2012 Code: mrl_az17_ro

Operating instructions and Declaration of conformity (sv) 491 kB, 07.08.2015 Code: mrl_az17_sv

Operating instructions and Declaration of conformity (jp) 749 kB, 24.09.2018 Code: mrl_az17_jp

Operating instructions and Declaration of conformity (it) 494 kB, 24.09.2018

Code: mrl_az17_it

Operating instructions and Declaration of conformity (da) 510 kB, 25.01.2012 Code: mrl_az17_da

Operating instructions and Declaration of conformity (br) 381 kB, 18.12.2018 Code: ace_mrl_az17_br

Operating instructions and Declaration of conformity (es) 496 kB, 24.09.2018 Code: mrl_az17_es

Operating instructions and Declaration of conformity (de) 486 kB, 05.04.2018 Code: mrl_az17_de

Operating instructions and Declaration of conformity (en) 495 kB, 24.09.2018 Code: mrl_az17_en

Operating instructions and Declaration of conformity (fr) 525 kB, 24.09.2018 Code: mrl_az17_fr

Operating instructions and Declaration of conformity (nl) 496 kB, 24.09.2018 Code: mrl_az17_nl

Operating instructions and Declaration of conformity (pt) 498 kB, 24.09.2018 Code: mrl_az17_pt

Operating instructions and Declaration of conformity (cs) 551 kB, 24.09.2018 Code: mrl_az17_cs

BG-test certificate (en) 159 kB, 26.11.2015 Code: z_z17p02


BG-test certificate (de) 181 kB, 26.11.2015 Code: z_z17p01

CCC certification (cn) 3 MB, 18.10.2017 Code: q_175p03

CCC certification (en) 3 MB, 29.08.2017 Code: q_175p02

EAC certification (ru) 844 kB, 05.10.2015 Code: q_6037p17_ru

Images



Dimensional drawing (basic component)

K.A. Schmersal GmbH & Co. KG, Möddinghofe 30, D-42279 Wuppertal The data and values have been checked throroughly. Technical modifications and errors excepted. Generiert am 13.02.2019 - 14:36:54h Kasbase 3.3.0.F.64l