



Model Number


UBE4000-30GM-SA2-V15

Features

- **Reliable detection of transparent** • materials
- High switching frequency
- Adjustable sensitivity •
- Adjustable switch-on delay •
- Small angle of divergence •
- **Protective functions** •
- Emitter and receiver included in the delivery package

Diagrams

Characteristic response curves



General specifications
Sensing range
Through-beam mode
Reference target
Transducer frequency
Indicators/operating mean
LED green

Technical data

LED yellow Electrical specifications Operating voltage UB No-load supply current I₀


Output Output type


Rated operating current Ie Voltage drop U_d Switch-on delay ton Switching frequency f Ambient conditions Ambient temperature

- Storage temperature
- Mechanical specifications
- Connection type
- Degree of protection Material
- Housing
- Mass
- Compliance with standards and directives Standard conformity
- Standards
- Approvals and certificates
- UL approval CSA approval
- CCC approval

Dimensions

Dimensions:





0...4000 mm, distance emitter-receiver 500 mm...4000 mm Single path ultrasonic switch receiver 85 kHz

UBE4000-30GM-SA2-V15

alignment aid OFF: no ultrasonic signal flashing: uncertain area ON: positive reception switching state

18 ... 30 V DC , ripple 10 $\%_{\rm SS}$ 35 mA emitter 25 mA receiver

2 switch outputs PNP, normally open/closed (complementary) 200 mA \leq 2.5 V 100 ... 3000 ms ≤ 15 Hz

0 ... 60 °C (32 ... 140 °F) -40 ... 85 °C (-40 ... 185 °F)

Connector M12 x 1 , 5-pin IP65

nickel plated brass; plastic components: PBT 160 g each sensor

EN 60947-5-2:2007 + A1:2012 IEC 60947-5-2:2007 + A1:2012

Receiver:

Plug connector

cULus Listed, General Purpose cCSAus Listed, General Purpose CCC approval / marking not required for products rated ≤36 V

fa-info@us.pepperl-fuchs.com

Refer to "General Notes Relating to Pepperl+Fuchs Product Information" USA: +1 330 486 0001

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



Dual-LED

green/yellow

Potentiometer

1


ON delay


Date of issue: 2016-04-18 120344_eng.xml Release date: 2016-04-18 10:43

Pepperl+Fuchs Group

www.pepperl-fuchs.com

Electrical Connection





Core colours in accordance with EN 60947-5-2.

Pinout

Wire colors in accordance with EN 60947-5-2

1	BN	(brown)
2	WH	(white)
3	BU	(blue)
4	BK	(black)
5	GY	(gray)

Accessories

FP100 Remote potentiometer

BF 30 Mounting flange, 30 mm

BF 5-30 Universal mounting bracket for cylindrical sensors with a diameter of 5 ... 30 mm

V1-G-2M-PVC Female cordset, M12, 4-pin, PVC cable

Description of the sensor functions


Remote potentiometer

The distance range of the through-beam ultrasonic barrier can be adjusted with the potentiometer integrated in the emitter, or via a remote potentiometer connected to the emitter.

The remote potentiometer simplifies the adjustment of the distance range if the sensors are installed in an inaccessible location. A 10 k Ω /0.3 W potentiometer serves as the remote potentiometer. The connection is realised using the plug connector pins 2 and 4 of the emitter (see: Electrical Connection).

Additional Information

Alignment



Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



The following distance ranges can be set using the remote potentiometer:

Adjustment of the internal distance regulator	Distance range adjustable via remote potenti- ometer
Minimum switching point	0 m 2 m
Maximum switching point	2 m 4 m

When operating without a remote potentiometer, the plug connector pins 2 and 4 must be bridged.

Adjustment

Turning the potentiometer on the emitter to the left (counterclockwise) causes a reduction of the transmission power. Thus, the through-beam ultrasonic barrier becomes more sensitive.

Note: If no remote potentiometer is connected and the connector pins 2 and 4 are not bridged, the emitter always operates at maximum transmission power. The through-beam ultrasonic barrier then has the lowest sensitivity. Turning the transmitter side potentiometer won't have an effect, then.

Alignment

When adjusting the emitter and receiver, take care to align them as precisely as possible.

Angular tolerance: $\alpha < \pm 2^{\circ}$ maximum offset: $s < \pm 5 mm$

A through-beam ultrasonic barrier consists of a single emitter and a single receiver.

Caution

Mount or replace emitter and receiver only in pairs. Both devices are optimally matched to each other by the manufacturer.

