

(€

VISC.

Model Number


ML9-54/59/82b/103/115a/134a

Retroreflective sensor 200 mm fixed cable with 4-pin, M8x1 connector


Features

- Ultra bright LEDs for power on, pre fault indication and switching state
- Flashing power on LED in case of short-circuit
- TEACH-IN
- Not sensitive to ambient light, even with switched energy saving lamps
- Protected against mutual interference (no cross-talk)
- Protection class II

Dimensions



Electrical connection




- O = Light on
- = Dark on

Pinout



Indicators/operating means



	1	LED green
	2	LED yellow
	3	Teach-In

Technical data		
General specifications		
Effective detection range		0 5 m
Threshold detection range		6 m
Reference target		H85-2 reflector
Light source		LED
Light type		modulated visible red light
Polarization filter		yes
Diameter of the light spot		approx. 110 mm at a distance of 3 m
Angle of divergence		approx. 2.1 °
Ambient light limit		30000 Lux
Functional safety related param	eters	
MTTF _d		1240 a
Mission Time (T _M)		20 a
Diagnostic Coverage (DC)		0 %
Indicators/operating means		
Operation indicator		LED green, statically lit Power on , Undervoltage indicator: Green LED, pulsing (approx. 0.8 Hz) , short-circuit : LED green flashing (approx. 4 Hz)
Function indicator		LED yellow, lights up when light beam is free, flashes when fal- ling short of the stability control
Control elements		Teach-In key
Electrical specifications		
Operating voltage	U_{B}	10 30 V DC , class 2
Ripple	_	max. 10 %
No-load supply current	I ₀	< 20 mA at 24 V
Output		
Pre-fault indication output		1 PNP, inactive when falling short of the stability control
Switching type		dark on
Signal output		1 PNP output, short-circuit protected, reverse polarity protected open collector
Switching voltage		max. 30 V DC
Switching current		max. 100 mA
Voltage drop	U _d	≤2 V DC
Switching frequency	f	1000 Hz
Response time		0.5 ms
Ambient conditions		
Ambient temperature		-25 60 °C (-13 140 °F)
Storage temperature		-40 75 °C (-40 167 °F)
Mechanical specifications		,
Degree of protection		IP67
Connection		200 mm fixed cable with 4-pin, M8x1 connector
Material		. ,
Housing		PC (glass-fiber-reinforced Makrolon)
Optical face		PMMA
Mass		approx. 25 g
Compliance with standards and ves	d directi	i-
Standard conformity		
Product standard		EN 60947-5-2:2007 IEC 60947-5-2:2007
Standards		EN 50178, UL 508
Approvals and certificates		
Protection class		II, rated voltage \leq 50 V AC with pollution degree 1-2 according to IEC 60664-1
UL approval		cULus

Accessories

OMH-ML9

Mounting bracket

OMH-ML9-01

Threaded bolt M3

V31-GM-2M-PVC

Female cordset, M8, 4-pin, PVC cable

V31-WM-2M-PVC

Female cordset, M8, 4-pin, PVC cable

V31-GM-5M-PUR

Female cordset, M8, 4-pin, PUR cable

V31-WM-5M-PUR

Female cordset, M8, 4-pin, PUR cable


Other suitable accessories can be found at www.pepperl-fuchs.com


EPPERL+FUCHS

CCC approval

CCC approval / marking not required for products rated ≤36 V

Curves/Diagrams





Setting Instructions

Setting Instructions for Devices with Teach-In

After the operating voltage is applied, the green LED lights up. The sensor is automatically in max. sensitivity status (state as supplied) or in the status of the most recent Teach-In setting.

Mount a suitable reflector opposite the photoelectric sensor.

Teach-In with the Teach key

- Align the sensor to a suitable reflector.
- · Press the Teach key. The green LED indicator light goes off briefly to confirm this.
- Hold down the Teach key until the yellow and green indicator LEDs flash synchronously (about 2.5 Hz). Then release the Teach key
- During internal setup of the sensor, the green and yellow indicator LEDs flash alternately (about 2.5 Hz).
- Teach-In successful: The green and yellow indicator LEDs are lit. The device is ready for operation.
- Teach-In not successful: The green and yellow indicator LEDs flash quickly and alternately (about 8 Hz) for about 5 seconds. Then the sensor switches to the status with maximum sensitivity. After that, repeat the Teach-In procedure, starting with step 1.