
Automation light grid





Model Number

LGS50

CE

Light grid

with fixed cable with 4-pin, M12 x 1 connector, and fixed cable with 8-pin, M12 x 1, connector


Features


- Automation light grid ٠
- Optical resolution 50 mm •
- Super-fast object detection, even with 3-way beam crossover
- Software-free adjustment of height monitoring
- Object identification using integrated object recognition
- IO-link interface for service and • process data
- Optional temperature range to -30 °C

Product information


The LGS automation light grid series detects objects ranging in size from small to large. The very slender light grids have a modular design and come in different beam spacings and field heights. All signal evaluation takes place inside the unit. The lightweight systems can be integrated in their surroundings in a well-designed configuration, which means that machines and plants in temperature ranges between -30 °C ... +60 °C can be designed more compactly.

Electrical connection






Pinout



Indicators/operating means



1	Menu button	yellow	7	Height checking 3	yellow
2	Operating indicator	green	8	Object floating	yellow
3	Status display	yellow	9	Crossing	yellow
4	Q object	yellow	10	Peripheral beam tolerance	yellow
5	Height checking 1	yellow	11	2nd level	yellow
6	Height checking 2	yellow	12	OK button	yellow

2nd level: Beam collimation, inverse mode, light-on/dark-on switching, reset factory setting, signal tracking

USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



LGS50

Technical data			Accessories
General specifications		Standard (0.2) C m	OMH-SLCT-01
Effective detection range		Standard : 0.3 6 m Option /35: 0.5 8 m	Quick clamp and
Threshold detection range		Standard : 7.5 m Option /35: 10 m	OMH-SLCT-06 Swivel Bracket
Light source		IRED	Swiver Dracket
Light type		modulated infrared light , 850 nm	V19-G-EMV-BK
Field height		see Table 1, max. 3000 mm	Double-ended c
Beam crossover Beam blanking		Factory setting: three beam crossing, deactivateable adjustable max. 2 fixed suppressible beam areas (blanking)	EMC filter, 8-pin
Beam spacing		50 mm	OMH-LGS-01
Number of beams		see Table 1, max. 61	Attachment aid f
Operating mode		Emitter: Emitter power adjustable in two ranges	LGM
Optical resolution		without beam crossover: 50 mm with beam crossover: 25 mm with in 25% and 75% of the range	OMH-SLCT-03
Angle of divergence Ambient light limit		10 ° > 50000 Lux (if external light source is outside the opening angle)	Mounting brack
Functional safety related para	meters	ange	OMH-SLCT-04 Mounting bracke
MTTF _d		56 a	(with loose bear
Mission Time (T _M)		20 a	,
Diagnostic Coverage (DC)		60 %	OMH-SLCT-05
Indicators/operating means			Mounting bracke
Operation indicator		Power on: LED green, statically lit , Undervoltage indicator: Green LED, pulsing (approx. 0.8 Hz) , short-circuit : LED green flashing (approx. 4 Hz)	AA SLCT-01 Profile alignmen
Function indicator		Emitter: Yellow LED, illuminates at high emitting power, off at low emitting power Receiver: Yellow LED: illuminates when an object is detected	of the SLCS and curtains
		flashes when falling short of the stability control (4 Hz) Error message: Yellow LED flashes (8 Hz) in emitter and receiver	V1-G-BK2M-PU
Control elements		Receiver: 2 touch buttons for programming	Female cordset,
Parameterization indicator		IO link communication: green LED goes out briefly (1 Hz)	V1-G-BK5M-PU
Electrical specifications			Female cordset,
Operating voltage	UB	18 30 V DC	V1-G-BK10M-P
Ripple No-load supply current	I ₀	10 % Emitter ≤: 50 mA	Female cordset,
Time delay before availability	t _v	Receiver: ≤ 150 mA (without outputs) see Table 1, max. 1.5 s	V1-G-BK15M-P Female cordset,
Interface Interface type		IO-Link	
Protocol		IO-Link V1.0	V19-G-BK10M-
Mode		COM 2 (38.4 kBaud)	Female cordset,
Input			V19-G-BK2M-P
Test input		Emitter switch-off with +UB or 0 V at pin 4 (emitter)	Female cordset,
Function input		Range input activation from 1.6 m (or 2 m in case of option /35) with +UB or 0 V on pin 2 (emitter) Teach-In input for programming on pin 8 (receiver)	V19-G-BK5M-P
Output			Female cordset,
Pre-fault indication output		Stability Control (SC) 1 PNP, short-circuit protected, reverse	V19-G-BK2M-P
		polarity protected on pin 2 (receiver)	Connection cab
Switching type		Factory setting: dark on , Switchable to light-on mode	PUR cable
Signal output		Switch output (detection field C/Q) 1 push-pull (4 in 1) output, short-circuit protected, reverse polarity protected on pin 4 (receiver),	IO-Link-Master
		Height monitoring (H1, H2. H3) 3 push-pull (4 in 1) outputs, short-circuit proof, reverse polarity protected on pin 5, pin 6, pin 7 (receiver)	IO-Link master, separate power
Switching threshold		Factory setting: The signal tracking for the threshold value is deactivated, increasing the optical resolution by a maximum of	M12 plug for ser
Switching voltage		4 mm; switchable to active signal tracking max. 30 V DC	Communication
Switching current		max. 100 mA	Master
Voltage drop	U _d	≤ 2 V DC	PACTware 4.1
Switching frequency	f	see Table 1, max. 129 Hz	FDT Framework
Response time		see Table 1, max. 8 ms	
Timer function		Off-delay programmable from 0 1.25 s in 5 ms steps (adjustment via IO-Link only)	IODD Interpret Software for the
Ambient conditions Ambient temperature		Standard : -10 60 °C (14 140 °F) Option /146: -30 60 °C (-22 140 °F)	frame applicatio
Storage temperature		-30 70 °C (-22 158 °F)	LGS IODD
Mechanical specifications			IODD for comm
Housing width		20 mm	Link sensors
Housing depth		30.5 mm	V1-G-BK0,6M-F
Housing length L		see Table 1, max. 3160 mm	Cordset, LGS25
Degree of protection		IP67	modules/WIS 2,

LGS50

MH-SLCT-01 uick clamp and adjustment system

19-G-EMV-BK0,3M-PVC-V19-G ouble-ended cordset, M12 to M12, with MC filter, 8-pin, PVC cable

MH-LGS-01 ttachment aid for light grid series LGS/ GΜ

MH-SLCT-03 ounting bracket including adjustment

MH-SLCT-04 ounting bracket including adjustment vith loose bearing)

MH-SLCT-05 ounting bracket including adjustment

A SLCT-01 rofile alignment aid; simplified alignment the SLCS and SLCT safety light irtains

1-G-BK2M-PUR-U emale cordset, M12, 4-pin, PUR cable

1-G-BK5M-PUR-U emale cordset, M12, 4-pin, PUR cable

1-G-BK10M-PUR-U emale cordset, M12, 4-pin, PUR cable

1-G-BK15M-PUR-U emale cordset, M12, 4-pin, PUR cable

19-G-BK10M-PUR-IEC emale cordset, M12, 8-pin, PUR-cable

19-G-BK2M-PUR-IEC emale cordset, M12, 8-pin, PUR-cable

19-G-BK5M-PUR-IEC emale cordset, M12, 8-pin, PUR-cable

19-G-BK2M-PUR-U-V1-G onnection cable, M12 to M12, 8/4-pin, UR cable

D-Link-Master02-USB D-Link master, supply via USB port or eparate power supply, LED indicators, 12 plug for sensor connection

D-Link-Master-USB DTM ommunication DTM for use of IO-Linkaster

ACTware 4.1 DT Framework

DDD Interpreter DTM oftware for the integration of IODDs in a ame application (e. g. PACTware)

GS IODD DDD for communication with LGS-IOnk sensors

1-G-BK0,6M-PUR-U-V1-G-LGS25T ordset, LGS25 light grids to ICE odules/WIS 2, M12 to M12, PUR cable,

Pepperl+Fuchs Group www.pepperl-fuchs.com

USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

4-pin Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



2

Connection	Emitter: 200 mm connecting cable with 4-pin, M12x1 connector Receiver: 200 mm connecting cable with 8-pin, M12 x 1 connector Cable cross section min. 0.25 mm ² Max. cable length 30 m
Material	
Housing	extruded aluminum section, Silver anodized
Optical face	Plastic pane, Polycarbonate
Mass	see Table 1, max. 1650 g (per profile)
Compliance with standards and directives	
Directive conformity	
EMC Directive 2004/108/EC	EN 60947-5-2:2007
Standard conformity	
Product standard	EN 60947-5-2:2007 IEC 60947-5-2:2007
Approvals and certificates	
Protection class	III (IEC 61140)
UL approval	cULus Listed
CCC approval	CCC approval / marking not required for products rated \leq 36 V


Operating principle

The light grid consists of a transmitter and a receiver, between which is the area to be monitored. The switch command is initiated by the entry or existence of a body/object in the monitoring field.

The modular system design supports a wide range of distances for the lines of light. Optimum implementation of the LGS series light grids for specific application requirements is thus possible.

The system also has 3 switch outputs for height checking. The system is programmed using the integrated touch field or the IO-Link interface.

Curves/Diagrams



Additional information

Table 1:

Switch-on delay, maximum switching frequency and maximum time delay before availability:

	· · · · · · · · · · · · · · · · · · ·						
23 232507	Field height [mm]		lelay Q [ms] parameterization	Switch-on delay Q [ms] with object parameterization, HQn outputs		Max. switching frequency [Hz]	Max. time delay before availability tv [s]
-02-2		typ.	max.	typ.	max.		
	300	3	4	5	7	129	0.8
issue:	600	3	5	5	7	118	0.9
OI IS	900	3	5	6	8	109	1.0
uate	1200	3	5	6	9	101	1.0
	1500	3	6	6	10	94	1.1
10:30	1800	3	6	7	10	88	1.2
62-20	2100	4	7	7	11	82	1.3
b	2400	4	7	7	12	78	1.3
	2700	4	7	8	13	73	1.4
e date	3000	4	8	8	13	70	1.5

Refer to "General Notes Relating to Pepperl+Fuchs Product Information" USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



Number of beams, housing length and weight:

Field height [mm]	Number of beams	Overall length of the transmitter/receiver unit [mm]	Weight of the transmitter/receiver unit [g]
300	7	460	300
600	13	760	450
900	19	1060	600
1200	25	1360	750
1500	31	1660	900
1800	37	1960	1050
2100	43	2260	1200
2400	49	2560	1350
2700	55	2860	1500
3000	61	3160	1650

Design and function

Safety information

The device must only be operated with Safety Extra Low Voltage (SELV) with safe electrical disconnection. Intervention and repairs must only be carried out by your suppliers.

The system must be serviced and checked regularly.

A clean, soft cloth can be used for cleaning. Aggressive, abrasive cleaning agents that damage the surface must be avoided. The device must not be subjected to hard knocks or vibration.

Commissioning

Prerequisites

- The transmitter and receiver must be installed and aligned correctly. •
- The electrical connection must be established according to the connection diagram.
- The signal output must respond to object detection.
- If at least one light beam is interrupted, the output remains active as long as the object is detected.

Fault location

- Measure operating voltage
- Check the cabling.
- Check the transmitter and receiver for dirt and clean if necessary.

Function displays

Behind the optics cover on the connection side of the profiles there is a green Power ON operating indicator LED and a yellow status display LED.

Transmitter

Function	Diagnostic description
Green operating indicator LED lights up statically	Power-On
Green operating indicator LED is dark and yellow status indi- cator flashes	Power save mode
Yellow status indicator LED is dark	Transmitter with low transmitting power
Yellow status indicator LED lights up statically	Transmitter with high transmitting power
Yellow status indicator LED flashes quickly (approx. 8 Hz)	Error condition
Yellow status indicator LED light changes for short time	Test input is activated

Receiver

4

Function	Diagnostic description
Green operating indicator LED lights up statically	Power-On
Green operating indicator LED is dark	Power save mode
Green operating indicator LED flashes with brief interruption	IO-Link mode active, parameterisation only possible via IO- Link
Green operating indicator LED flashes (4 Hz)	Error condition: Short circuit at the outputs
Yellow status indicator LED lights up statically	Detection field interrupted
Yellow status indicator LED is dark	Detection field is enabled.
Yellow status indicator LED flashes (approx. 4 Hz)	Insufficient function reserve
Yellow status indicator LED flashes quickly (approx. 8 Hz)	Error condition: Incorrect signal measurement

Resolution and beam clearance




The mechanical beam clearance determines the smallest detectable object size. Crossing the light beams increases the resolution of the light grid.


The devices are delivered without programmed height checking. The beam is crossed three times.

Resolution of the crossed beam arrangement

If three-way crossing of the beams is programmed, the resolution increases. For a three-way crossing, this means that the increased resolution is offered after 25% of the transmitter range or receiver range. It must therefore be ensured that all objects pass transmitters or receivers with this clearance.







www.pepperl-fuchs.com



6