Features

- 1-channel
- Input for frequency, counter, direction of rotation
- Installation in Zone 2 or safe area
- Digital input max. 400 Hz
- Positive or negative logic selectable
- Simulation mode for service operations (forcing)
- · Line fault detection (LFD)
- · Permanently self-monitoring
- Module can be exchanged under voltage


Function

The device accepts digital input signals of NAMUR sensors or mechanical contacts from the field.

Open or short circuit line fault alarms are detected.


The inputs are galvanically isolated from the bus and the power supply (EN 60079-11).


Assembly





Connection





Zone 2

Slots		
Occupied slots		1
Supply		
Connection		backplane bus
Rated voltage	U_r	12 V DC, only in connection with the power supplies LB9***
Power dissipation		0.65 W
Power consumption		0.65 W
Internal bus		
Connection		backplane bus
Interface		manufacturer-specific bus to standard com unit
Digital input		manufacturer opcome such a cumulate com unit
Number of channels		1
Function		
Function		Counter
Function [2]		frequency
Function [3]		direction of rotation
Sensor interface		
Connection		NAMUR sensor
Connection [2]		volt-free contact
Connection [3]		active binary signal 24 V DC
Connection		channel I: 1+, 2-; direction: 4+, 5-
Rated values		acc. to EN 60947-5-6 (NAMUR)
Switching point/switching hyst	eresis	1.2 2.1 mA/±0.2 mA
Voltage		8.2 V
Internal resistor	Ri	1 kΩ
Line fault detection		can be switched on/off for each channel via configuration tool
Connection		mechanical switch with additional resistors (see connection diagram) proximity switches without additional wiring
Short-circuit		< 360 Ω
Open-circuit		< 0.35 mA
Minimum pulse duration		; in frequency + counter mode: 12.5 ms ; otherwise 20 μs
Operating frequency		0 400 Hz ; in frequency + counter mode 40 Hz
Indicators/settings		o 400 Hz ; il rioquelloy i counter mode 40 Hz
LED indication		Power LED (P) green: supply
LLD Indication		Status LED (1) red: line fault
Coding		optional mechanical coding via front socket
Directive conformity		opnoral moonalista county has nonecond
Electromagnetic compatibility		
Directive 2014/30/EU		EN 61326-1
Conformity		LN 01020-1
•		NE 21
Electromagnetic compatibility		
Degree of protection		IEC 60529
Environmental test		EN 60068-2-14
Shock resistance		EN 60068-2-27
Vibration resistance		EN 60068-2-6
Damaging gas		EN 60068-2-42
Relative humidity		EN 60068-2-56
Ambient conditions		
Ambient temperature		-20 60 °C (-4 140 °F) , 70 °C (non-Ex)
Storage temperature		-25 85 °C (-13 185 °F)
Relative humidity		95 % non-condensing
Shock resistance		shock type I, shock duration 11 ms, shock amplitude 15 g, number of shocks 18
Vibration resistance		frequency range 10 150 Hz; transition frequency: 57.56 Hz, amplitude/acceleration ± 0.075 mm/1 g; 10
		cycles
		frequency range 5 100 Hz; transition frequency: 13.2 Hz amplitude/acceleration ± 1 mm/0.7 g; 90 minutes at
Domosing		each resonance
Damaging gas		designed for operation in environmental conditions acc. to ISA-S71.04-1985, severity level G3
Mechanical specifications		IDOO where we would are be advalage.
Degree of protection		IP20 when mounted on backplane
Connection		removable front connector with screw flange (accessory) wiring connection via spring terminals (0.14 1.5 mm²) or screw terminals (0.08 1.5 mm²)
Mass		approx. 90 g
Dimensions		16 x 100 x 102 mm (0.63 x 3.9 x 4 inch)
Data for application in conn	ection	
with hazardous areas		
Certificate		PF 08 CERT 1234 X

PEPPERL+FUCHS
PROTECTING YOUR PROCESS

Marking	(Ex) II 3 G Ex nA [ic] IIC T4 Gc
Galvanic isolation	
Input/power supply, internal bus	safe electrical isolation acc. to EN 60079-11, voltage peak value 375 V
Directive conformity	
Directive 2014/34/EU	EN 60079-0:2009 EN 60079-11:2007 EN 60079-15:2010
International approvals	
ATEX approval	PTB 03 ATEX 2042
IECEx approval	BVS 09.0037X
Approved for	Ex nA [ic] IIC T4 Gc
Marine approval	
Lloyd Register	15/20021
DNV GL Marine	TAA0000034
Bureau Veritas Marine	22449/B0 BV
General information	
System information	The module has to be mounted in appropriate backplanes (LB9***) in Zone 2 or outside hazardous areas. Here, observe the corresponding declaration of conformity. For use in hazardous areas (e. g. Zone 2 or Zone 22) the module must be installed in an appropriate enclosure.
Supplementary information	EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperl-fuchs.com.