











### **Model Number**

#### VDM100-50-EIP/G2

Distance sensor with three M12 x 1 connectors


### **Features**


- Measuring method PRT (Pulse Ranging Technology)
- Non-contact precision measurement
- Ultra-fast data acquisition
- Active dynamic control
- Modern lightweight design, extremely robust
- EtherNet/IP

### **Product information**


Series VDM 100 laser distance measurement devices are designed for high distances. They have a repeat accuracy of 0.5 mm. SSI and fieldbusses are used as value interfaces. These devices are used for precise positioning of rack operating units, gantry cranes, rail-bound vehicles, elevators and other linear movable units.

### **Dimensions**






## **Electrical connection**



# Indicators/operating means



1	Power-LED	green
2	Display	
3	TARGET-LED	green
4	ERROR-LED	red
5	BUS-LED	green
6	Control keys	

www.pepperl-fuchs.com

#### **Technical data** General specifications Measurement range 0.3 ... 50 m Foil reflector 500 mm x 500 mm Reference target laser diode Light source Laser nominal ratings VISIBLE AND INVISIBLE LASER RADIATION, DO NOT STARE Note INTO BEAM Laser class Measurement laser: 1 Alignment laser: 2 Measurement laser: 905 nm Wave length Alignment laser: 660 nm Beam divergence Measurement laser: 2 mrad Alignment laser: 1 mrad Pulse length Measurement laser: 4 ns Measurement laser: 20 kHz Repetition rate Maximum optical power output Alignment laser: 0.6 mW Measurement laser: 12 nJ max. pulse energy Pulse Ranging Technology (PRT) Measuring method Max. Motion velocity Alignment aid Laser pointer Life span > 100000 h Diameter of the light spot < 15 cm at 50 m Ambient light limit > 100000 Lux Resolution 0.1 mm, adjustable Temperature influence 0.03 mm/K Functional safety related parameters 120 a $MTTF_d$ Mission Time (T<sub>M</sub>) 20 a Diagnostic Coverage (DC) 0 % Indicators/operating means Diagnostics indicator 3 LEDs connection status: Link, speed, activity Function indicator Control elements Control panel (4 membrane keys) for setting parameters status Parameterization indicator Illuminated display for displaying measured values and parameterization **Electrical specifications** 18 ... 30 V DC Operating voltage $U_B$ No-load supply current 250 mA (18 V) ... 150 mA (30 V) $I_0$ Protection class III (operating voltage 50 V) Time delay before availability < 10 s $t_v$ Interface Interface type EtherNet/IP 1000/s @ 100 Mbit/s Read out rate Input/Output Input/output type 2 PNP inputs/outputs, independent configuration, short-circuit protected, reverse polarity protected Input Switching threshold low: Ue < 6 V. high: Ue > 16 V Output Switching threshold low: Ua < 1 V, high: Ua > Ub - 1 V Switching current 200 mA per output Measurement accuracy Measured value output Average data age 3 ms, 6 ms, 12 ms, 25 ms, 50 ms, adjustable Offset max. 2 mm (between two devices) Absolute accuracy ± 2.5 mm (> 3 m); ± 3.5 mm (0.3 m to 3 m) < 0.5 mm Repeat accuracy **Ambient conditions** Ambient temperature -10 ... 50 °C (14 ... 122 °F) Storage temperature -20 ... 70 °C (-4 ... 158 °F) Relative humidity 95 %, no moisture condensation **Mechanical specifications** Degree of protection IP65 4-pin, M12x1 connector, standard (supply), Connection 4-pin, M12x1 socket, D-coded (LAN), 8-pin, M12x1 connector, service Material Housing ABS / PC PMMA, hard coated Optical face Mass approx. 700 g Compliance with standards and directives Directive conformity

#### Laserlabel

VISIBLE AND INVISIBLE LASER RADIATION
DO NOT STARE INTO BEAM
CLASS 2 LASER PRODUCT
INFO LASER 2:
WAVELENGTH: 8956m WWELENGTH: 660nm
WAVELENGTH: 660nm WWELENGTH: 660nm
WAVELENGTH: 660nm WWELENGTH: 660nm
PULSE DIRECTOR 470
IEC 60025-1: 2007 CERTIFIED.
COMPLIES WITH 21 CFR 1004,10 AND 1040,11 EXCEPT
FOR DEVIATIONS PURSUANT TO LASER NOTICE NO. 50,
DATED JUNE 24, 2007.

#### **Accessories**

### V15-G-PG9

Female connector, M12, 5-pin, field attachable

#### V1SD-G-2M-PUR-ABG-V45-G

Connection cable, M12 to RJ-45, PUR cable 4-pin, CAT5e

#### V1SD-G-5M-PUR-ABG-V45-G

Connection cable, M12 to RJ-45, PUR cable 4-pin, CAT5e

### V1SD-G-2M-PUR-ABG-V1SD-G

Ethernet bus cable, M12 to M12, PUR cable 4-pin, CAT5e

#### V1SD-G-ABG-PG9

Cable connector, M12, 4-pin, D-coded, shielded, non pre-wired

#### OMH-LS610-01

Mounting bracket for optical data coupler

#### OMH-VDM100-01


Mounting bracket with deviation mirror for distance measurement devices


Other suitable accessories can be found at www.pepperl-fuchs.com



EMC Directive 2004/108/EC	EN 60947-5-2:2007		
Standard conformity			
Product standard	EN 60947-5-2:2007		
Laser class	IEC 60825-1:2007 Complies with 21 CFR 1040.10 and 1040.11 except for deviations pursuant to Laser Notice No. 50, dated June 24, 2007		
Approvals and certificates			
• •	cl II us Listed Class 2 Power Source Type 1 enclosure		
	IEC 60825-1:2007 Complies with 21 CFR 1040.10 and 1040.1 except for deviations pursuant to Laser Notice No. 50, dated		

### **Curves/Diagrams**





### Laser notice laser class 2

- Caution: visible and invisible laser radiation, do not look at the beam!
- The irradiation can lead to irritation especially in a dark environment. Do not point at people!
- Maintenance and repairs should only be carried out by authorized service personnel!
- · Attach the device so that the warning is clearly visible and readable.
- Caution Use of controls or adjustments or performance of procedures other than those specified herein may result in hazardous radiation
  exposure.