Dimensions





Model Number

OBR2000-R2-E2-L


Laser retroreflective sensor with 2 m fixed cable

Features

- Ultra-small housing design
- DuraBeam Laser Sensors durable ٠ and employable like an LED
- 45° cable outlet for maximum mounting freedom under extremely tight space constraints
- Improvement in machine availability ٠ with abrasion-resistant, antistatic glass front

Product information


The nano sensor has been developed for a broad range of applications. It offers excellent durability and is exceptionally easy to install. The housing is compact and, with its 45° cable outlet, can be installed in the smallest spaces. New functional principles and functionality open up a range of new options. The abrasion-resistant lens allows long operating times close to the moving object.



Electrical connection



Indicators/operating means



| 1 | Operating display | green |
|---|-------------------|--------|
| 2 | Signal display | yellow |
| 3 | Emitter | |
| 4 | Receiver | |

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Pepperl+Fuchs Group www.pepperl-fuchs.com

USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com




| | | | Laserlabel |
|---------------------------------------|----------------|---|---|
| General specifications | | | |
| Effective detection range | | 0 2 m | |
| Reflector distance | | 40 2000 mm | |
| Threshold detection range | | 2.3 m | CLASS 1 LASER |
| Reference target | | H40 reflector | PRODUCT |
| Light source | | laser diode | |
| Light type | | modulated visible red light, 680 nm | |
| Polarization filter | | yes | |
| Laser nominal ratings | | | |
| Note | | LASER LIGHT , DO NOT STARE INTO BEAM | CLASS 1 |
| Laser class | | 1 | LASER PRODUCT |
| Wave length | | 680 nm | IEC 60825-1: 2007 certified. |
| Beam divergence | | > 5 mrad | Complies with 21 CFR 1040.10 and 1040.11 except |
| Pulse length Repetition rate | | approx. 3 μs approx. 16.6 kHz | for deviations pursuant to Laser Notice No. 50, |
| max. pulse energy | | 8 nJ | dated June 24, 2007 |
| Diameter of the light spot | | approx. 35 mm at a distance of 2000 mm | |
| Angle of divergence | | approx. 0.5 ° | |
| Optical face | | frontal | |
| Ambient light limit | | EN 60947-5-2 : 30000 Lux | |
| Functional safety related parar | notore | | CLASS 1 |
| MTTF _d | lieleis | 800 a | |
| Mission Time (T _M) | | 20 a | LASER PRODUCT |
| Diagnostic Coverage (DC) | | 0% | IEC 60825-1: 2007 certified. |
| Indicators/operating means | | 0 /0 | Complies with 21 CFR 1040.10 and 1040.11 except for deviations pursuant to |
| Operation indicator | | LED green, statically lit Power on , short-circuit : LED green | Laser Notice No. 50, dated June 24, 2007 |
| Operation indicator | | flashing (approx. 4 Hz) | |
| Function indicator | | LED yellow: lights up when receiving the light beam ; flashes | |
| | | when falling short of the stability control; OFF when light beam is | |
| | | interrupted | Accessories |
| Electrical specifications | | | Accessories |
| Operating voltage | UB | 12 24 V | MH-R2-01 |
| No-load supply current | I ₀ | < 10 mA | Mounting aid for R2 series, Mounting |
| Protection class | | 11 | bracket |
| Output | | | MUL Do oo |
| Switching type | | NO contact | MH-R2-02 |
| Signal output | | 1 PNP output, short-circuit protected, reverse polarity protected, open collector | Mounting aid for R2 series, Mounting |
| Switching voltage | | max. 30 V DC | bracket |
| Switching current | | max. 50 mA , resistive load | MH-R2-03 |
| Voltage drop | U _d | $\leq 1.5 \text{ V DC}$ | Mounting aid for R2 series, Mounting |
| Switching frequency | f | approx. 2 kHz | |
| Response time | | 250 μs | bracket |
| Directive conformity | | / | MH-R2-04 |
| Electromagnetic compatibility | | | Mounting aid for R2 series, Mounting |
| Directive 2014/30/EU | | EN 60947-5-2:2007 EN 60947-5-2/A1:2012 | bracket |
| Standard conformity | | | bracher |
| Standards | | EN 60947-5-2:2007 EN 60947-5-2/A1:2012 EN 60825-1:2007 | REF-H40 |
| Otandardo | | UL 60947-5-2: 2014 | Reflector, rectangular 47.5 mm x 23.5 |
| Ambient conditions | | | mm, mounting holes, fixing strap |
| Ambient temperature | | -20 60 °C (-4 140 °F) | |
| Storage temperature | | -30 70 °C (-22 158 °F) | REF-H23 |
| Mechanical specifications | | | Reflector with mounting holes |
| Housing width | | 7.5 mm | |
| Housing height | | 24 mm | REF-MH20 |
| Housing depth | | 11.2 mm | Reflector with Micro-structure, |
| Degree of protection | | IP67 | rectangular 32 mm x 20 mm, mounting |
| Connection | | 2 m fixed cable | holes |
| Material | | | REF-MH23 |
| Housing | | PC/ABS and TPU | |
| Optical face | | glass | Reflector with Micro-structure, |
| Cable | | PUR | rectangular 23 mm x 13.8 mm, diagona |
| Installation | | Fixing screws, 2 x M2 allen head screws included with delivery | mounting hole |
| Mass | | approx. 20 g | Other suitable accessories can be found |
| Cable length | | 2 m | www.pepperl-fuchs.com |
| , , , , , , , , , , , , , , , , , , , | | | |
| Approvals and certificates | | | |
| UL approval | | E87056, cULus Recognized, Class 2 Power Source | |
| CCC approval | | CCC approval / marking not required for products rated \leq 36 V | |
| FDA approval | | IEC 60825-1:2007 Complies with 21 CFR 1040.10 and | |
| | | 1040.11 except for deviations pursuant to Laser Notice No. | |

pt bu GU the base date: 2017-10-23 11:28 Date of issue: 2017-10-23 282035_eng.xml

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com

PEPPERL+FUCHS SENSING YOUR NEEDS



Laser notice laser class 1

- The irradiation can lead to irritation especially in a dark environment. Do not point at people!
- Maintenance and repairs should only be carried out by authorized service personnel!
- Attach the device so that the warning is clearly visible and readable. ٠
- The warning accompanies the device and should be attached in immediate proximity to the device. ٠
- Caution - Use of controls or adjustments or performance of procedures other than those specified herein may result in hazardous radiation exposure.

