







Model Number

OBE1000-R2-SE2-0,2M-V31-L

Laser thru-beam sensor with fixed cable and 4-pin, M8 connector


Features

- Ultra-small housing design
- DuraBeam Laser Sensors durable and employable like an LED
- 45° cable outlet for maximum mounting freedom under extremely tight space constraints
- Improvement in machine availability with abrasion-resistant, antistatic glass front


Product information


The R2 series nano sensor has been developed for a broad range of applications. It offers excellent durability and is exceptionally easy to install. The housing is compact and, with its 45° cable outlet, can be installed in the smallest spaces. New functional principles and functionality open up a range of new options. The DuraBeam laser sensors are durable and can be used in the same way as a standard sensor. The abrasion-resistant lens allows long operating times close to the moving object.

Dimensions



Electrical connection






Pinout

Wire colors in accordance with EN 60947-5-2



1	BN	(brown)	
2	WH	(white)	
3	BU	(blue)	
4	BK	(black)	
		(=)	

Indicators/operating means



1	Operating display	green
2	Signal display	yellow
3	Emitter	
4	Receiver	

Technical data System components Emitter OBE10M-R2-0M2-V31-L OBE1000-R2-E2-0M2-V31-L General specifications Effective detection range 0 1 m Threshold detection range 1.5 m laser diode Light source Light type modulated visible red light, 680 nm Laser nominal ratings Note LASER LIGHT, DO NOT STARE INTO BEAM Laser class 680 nm Wave length Beam divergence > 5 mrad Pulse length approx. 2 us Repetition rate approx. 16.6 kHz max. pulse energy 9.5 nJ Diameter of the light spot approx. 3 mm at a distance of 1000 mm Angle of divergence approx. 0.5 ° Optical face frontal EN 60947-5-2: 30000 Lux Ambient light limit Functional safety related parameters 806 a $MTTF_d$ Mission Time (T_M) 20 a Diagnostic Coverage (DC) 0 % Indicators/operating means Operation indicator LED green, statically lit Power on , short-circuit : LED green flashing (approx. 4 Hz) Receiver: LED yellow, lights up when light beam is free, flashes Function indicator when falling short of the stability control; OFF when light beam is interrupted **Electrical specifications** Operating voltage U_{B} 12 ... 24 V No-load supply current Emitter: ≤ 10 mA I_0 Receiver: ≤ 8 mA Protection class Input Test input Test of switching function at 0 V Switching threshold Teach-In input Output Switching type NO contact Signal output 1 PNP output, short-circuit protected, reverse polarity protected, open collector Switching voltage max. 30 V DC Switching current max. 50 mA, resistive load ≤ 1.5 V DC Voltage drop Switching frequency approx. 2 kHz Response time 250 us Directive conformity Electromagnetic compatibility Directive 2014/30/EU EN 60947-5-2:2007 EN 60947-5-2/A1:2012 Standard conformity Standards EN 60947-5-2:2007 EN 60947-5-2/A1:2012 EN 60825-1:2007 UL 60947-5-2: 2014 **Ambient conditions** -20 ... 60 °C (-4 ... 140 °F) Ambient temperature -30 ... 70 °C (-22 ... 158 °F) Storage temperature Mechanical specifications Degree of protection **IP67** Connection 200 mm fixed cable with 4-pin, M8x1 connector Material Housing PC/ABS and TPU Optical face glass PUR Cable Installation Fixing screws, 2 x M2 allen head screws included with delivery approx. 10 g Per sensor Mass Cable length 200 mm Approvals and certificates

Laserlabel



CLASS 1 LASER PRODUCT

IEC 60825-1: 2007 certified. Complies with 21 CFR 1040.10 and 1040.11 except for deviations pursuant to Laser Notice No. 50. dated June 24, 2007

CLASS 1 LASER PRODUCT

IEC 60825-1: 2007 certified. Complies with 21 CFR 1040.10 and 1040.11 except for deviations pursuant to Laser Notice No. 50, dated June 24, 2007

Accessories

V31-WM-2M-PUR

Female cordset, M8, 4-pin, PUR cable

Mounting aid for R2 series, Mounting bracket

MH-R2-02

Mounting aid for R2 series, Mounting bracket

MH-R2-03

Mounting aid for R2 series, Mounting bra-

MH-R2-04

Mounting aid for R2 series, Mounting bra-

Other suitable accessories can be found at www.pepperl-fuchs.com

PEPPERL+FUCHS



UL approval

CCC approval

FDA approval


dated June 24, 2007


E87056, cULus Recognized, Class 2 Power Source

IEC 60825-1:2007 Complies with 21 CFR 1040.10 and 1040.11 except for deviations pursuant to Laser Notice No. 50,

CCC approval / marking not required for products rated ≤36 V

Curves/Diagrams





Teach-In Methods

The thru-beam sensor enables the switching points to be taught in for optimum adaptation to specific applications. This eliminates the need for additional components such as apertures.

The sensitivity of the thru-beam sensor can be adjusted using three Teach-in methods:

Position Teach

2017-03-02 282042_eng.xml


Date of issue:

2017-03-02 15:31

When using this Teach-in method, the following settings are made on the thru-beam sensor:

- · The gain is set to an optimum value
- The signal threshold is set to a minimum





Recommended application:

This method enables minuscule particles in the beam path to be detected, and provides exceptional positioning accuracy.


Make sure that there are no objects in the beam path and that the sensor is connected to the power supply.

- . Connect the white cable on the receiver (WH/IN) to the blue cable (BU/0 V) on the receiver. The green and yellow LED indicators flash simultaneously at 2.5 Hz
- Disconnect the white cable on the receiver (WH/IN) from the blue cable (BU/0 V) on the receiver.
 The green and yellow LED indicators flash alternately at 2.5 Hz
- 3. The end of the Teach-in process is indicated when the green LED indicator lights up sold and yellow LED blinks.

Two-Point Teach-In

When using this Teach-in method, the following settings are made on the thru-beam sensor:

- The gain is set to an optimum value
- The signal threshold is set in the center between the two taught signal values





- 1. Make sure that there are no objects in the beam path and that the sensor is connected to the power supply.
- Connect the white cable on the receiver (WH/IN) to the blue cable (BU/0 V) on the receiver. The green and yellow LED indicators flash simultaneously at 2.5 Hz
- Position the object in the beam path.
- Disconnect the white cable on the receiver (WH/IN) from the blue cable (BU/0 V) on the receiver. The green and yellow LED indicators flash alternately at 2.5 Hz
- The end of the Teach-in process is indicated when the green LED indicator lights up sold. 5.

Maximum Teach-In

When using this Teach-in method, the following settings are made on the thru-beam sensor:

- The gain is set to a maximum
- The signal threshold is set to a minimum





Recommended application:

Enables an object to be detected with a high excess gain. This can be useful if there is severe environmental contamination or to achieve long operating times.

Make sure that there are no objects in the beam path and that the sensor is connected to the power supply.

- 6. Cover the receiver or transmitter.
- Connect the white cable on the receiver (WH/IN) to the blue cable (BU/0 V) on the receiver. The green and yellow LED indicators flash simultaneously at 2.5 Hz
- Disconnect the white cable on the receiver (WH/IN) from the blue cable (BU/0 V) on the receiver. The green and yellow LED indicators flash alternately at 2.5 Hz
- 9. The end of the Teach-in process is indicated when the green LED indicator lights up sold.

Laser notice laser class 1

- The irradiation can lead to irritation especially in a dark environment. Do not point at people!
- Maintenance and repairs should only be carried out by authorized service personnel!
- Attach the device so that the warning is clearly visible and readable.
- The warning accompanies the device and should be attached in immediate proximity to the device.
- Caution Use of controls or adjustments or performance of procedures other than those specified herein may result in hazardous radiation exposure.

