Datasheet - SVE2/xxx-115VAC

Key transfer system / SVE - Key selector switch - Interlocking equipment





(Minor differences between the printed image and the original product may exist!)

- · Thermoplastic enclosure
- Protection class IP65

Ordering details

Product type description

Article number

EAN Code

notice

SVE2/xxx-115VAC

SVE2/xxx-115VAC

In the order/inquiry the requested lock number "xxx" must be specified (e.g. SVE2/115/115-115VAC)!

If no lock number is indicated in the order/inquiry, we will supply a lock number at our discretion.

The user must ensure that lock numbers are not assigned twice in a single plant (factory site)!

The user must ensure that no double key bit numbers are allocated on one site (company site)!

27-27-26-03

eCl@ss

Classification

Standards

B10d Normally-closed contact (NC)

Mission time

notice

EN ISO 13849-1

100.000

20 Years

$$MTTF_d = \frac{B_{10d}}{0.1 \times n_{op}}$$

$$n_{op} = \frac{d_{op} \times h_{op} \times 3600 \text{ s/h}}{t_{oyole}}$$

Global Properties

Permanent light

Standards

Compliance with the Directives (Y/N) $\zeta \in$

Number of key selector switch

Active principle

Duty cycle

Schlüssel-Wahlschalter

IEC/EN 60947-1, IEC 60947-5-1, EN 1088

Yes

2

electromechanical

Magnet 100

Materials

- Material of the housings Plastic, glass-fibre reinforced thermoplastic, self-extinguishing

- Material of the contacts Silver None Housing coating

Enclosure color Black / Silver

Color

Silver - Colour of the key grip Silver - Colour of the key

Weight 750 Key number XXX Key selector switch position left, right

Included in standard version Locking system

Mechanical data

Connection type Screw connection

Cable section

0,25 - Min. Cable section - Max. Cable section 2.5

Mechanical life 100.000 operations

notice All indications about the cable section are including the conductor ferrules.

4 A

Emergency unlocking device (Y/N) No Manual release (Y/N) Yes Emergency release (Y/N) No

Ambient conditions

Ambient temperature

0 - Min. environmental temperature - Max. environmental temperature +50

Protection class IP65 / IP20 to IEC/EN 60529

Electrical data

Thermal test current

Design of control element Normally open contact (NO), Opener (NC)

Switching principle Creep circuit element

Number of auxiliary contacts 3 Number of safety contacts 2 Power to unlock Yes Power to lock Nο Rated control voltage 115 Power consumption 8.5 Rated impulse withstand voltage 2.5 Rated insulation voltage 250

Utilisation category AC-15: 230 V / 4 A, DC-13: 24 V / 4 A

Max. fuse rating 4 A gG D-fuse To DIN EN 60269-1

NC contacts in series notice

ATEX

Explosion protection categories for gases None None

Explosion protected category for dusts

Dimensions

Dimensions of the sensor

- Width of sensor- Height of sensor169

- Height of sensor- Length of sensor144

Included in delivery

Key and triangular tool included in delivery (incl. 1 key for emergencies)

notice - Operating principle

see drawing: **Operating principle** Key 1-3 in Pos. 1, magnet de-energised: key-operated switch locked, NC

contacts closed, key not withdrawable

Key 1-3 in Pos. 1, magnet energised NC contact open: key-operated switch unlocked, NC contacts closed, key not withdrawable Key 1-3 in Pos. 2, magnet energised NC contact open: key-operated

switch unlocked, NC contacts open, key withdrawable

Triangular tool for manual release in Pos. 3: key-operated switch mechanically locked, magnet non-operational, NC contact open Triangular tool for manual release in Pos.4: magnet operational

Ordering code

SVE(1)(2)(3)/(4)(5)(6)-(7)

notice

Not all variations can be supplied.

The available order code used to convert the product part name.

(1)

1 1 Key selector switch 2 2 Key selector switch

3 Key selector switch

(2)

3

without Included in standard version Locking system
-ZI Central locking system-Locking system

(3)

without Included in standard version Silver

SR/

xx Key number (n) 100 ... 999

XXX

00/00

(5)

Colour of the key grip
(BR)

(GB)

(RT)

(BL)

(WS)

(GR)

(GN)

(SW)

and all combinations resulting thereof

(6)

-30E

without Magnet: 1 Opener (NC) / 1 Normally open contact (NO)

Key selector switch: 1 Opener (NC) / 1 Normally open contact (NO)

Magnet: 1 Opener (NC) / 1 Normally open contact (NO)

Key selector switch 2 Opener (NC) / 1 Normally open contact (NO)

Magnet: 1 Opener (NC) / 1 Normally open contact (NO)

Key selector switch 2 Opener (NC) / 1 Normally open contact (NO)

(7)

-W

 24VDC
 Us 24 VDC

 24VAC
 Us 24 VAC

 115VAC
 Us 115 VAC

 230VAC
 Us 230 VAC

Documents

Operating instructions and Declaration of conformity (da) 2 MB, 25.09.2015

Code: mrl_shgv-sve-svm_da

Operating instructions and Declaration of conformity (es) 2 MB, 22.08.2016

Code: mrl_shgv-sve-svm_es

Operating instructions and Declaration of conformity (jp) 2 MB, 23.03.2017

Code: mrl_shgv-sve-svm_jp

Operating instructions and Declaration of conformity (de) 2 MB, 25.07.2016

Code: mrl_shgv-sve-svm_de

Operating instructions and Declaration of conformity (fr) 2 MB, 16.09.2016

Code: mrl_shgv-sve-svm_fr

Operating instructions and Declaration of conformity (nl) 2 MB, 08.08.2018

Code: mrl_shgv-sve-svm_nl

Operating instructions and Declaration of conformity (en) 2 MB, 25.07.2016

Code: mrl_shgv-sve-svm_en

Operating instructions and Declaration of conformity (pt) 2 MB, 23.08.2016

Code: mrl_shgv-sve-svm_pt

Operating instructions and Declaration of conformity (cn) 2 MB, 27.07.2017

Code: mrl_shgv-sve-svm_cn

Operating instructions and Declaration of conformity (pl) $2\ MB,\,22.11.2016$

Code: mrl_shgv-sve-svm_pl

Operating instructions and Declaration of conformity (it) 2 MB, 02.09.2016

Code: mrl_shgv-sve-svm_it


CCC certification (cn) 2 MB, 29.10.2018

Code: q_svep03


CCC certification (en) 2 MB, 29.10.2018

Code: q_svep02


Images




Dimensional drawing (basic component)




Dimensional drawing (basic component)



Dimensional drawing (basic component)



Wiring example



K.A. Schmersal GmbH & Co. KG, Möddinghofe 30, D-42279 Wuppertal The data and values have been checked throroughly. Technical modifications and errors excepted. Generiert am 13.02.2019 - 13:09:48h Kasbase 3.3.0.F.64l