# Datasheet - AZ 17-02ZRK

Safety switch with separate actuator / AZ 17







- ullet Double-insulated lacktriangle
- Long life
- 30 mm x 60 mm x 30 mm
- Small body
- · Multiple coding
- High level of contact reliability with low voltages and currents
- · Insensitive to soiling
- 8 actuating planes
- cable gland M16



(Minor differences between the printed image and the original product may exist!)

# **Ordering details**

 Product type description
 AZ 17-02ZRK


 Article number
 101133968

 EAN Code
 4030661050959

 eCl@ss
 27-27-26-02

## **Approval**

Approval



#### Classification

Standards

B10d Normally-closed contact (NC)

Mission time

notice

EN ISO 13849-1

2.000.000

20 Years

$$MTTF_d = \frac{B_{10d}}{0.1 \times n_{op}}$$

$$n_{op} = \frac{d_{op} \times h_{op} \times 3600 \text{ s/h}}{t_{ovole}}$$

#### **Global Properties**

Permanent light AZ 17

Standards EN 60947-5-1, BG-GS-ET-15

Materials

- Material of the housings Plastic, glass-fibre reinforced thermoplastic, self-extinguishing

- Material of the contacts Silver

Housing coating None Weight 85

#### **Mechanical data**

Design of electrical connection IDC method of termination

Cable section

- Min. Cable section 1 x 0,75- Max. Cable section 1 x 1

Mechanical life > 1.000.000 operations

higher Latching force (Y/N)

Latching force

30

Positive break force

17 N

positive break travel

11 mm

Max. Actuating speed

2 m/s

## **Ambient conditions**

Protection class IP67 to IEC/EN 60529

#### **Electrical data**

Design of control element Opener (NC)

Switching principle Creep circuit element

Number of auxiliary contacts0Number of safety contacts2Rated impulse withstand voltage Uimp4 kVRated insulation voltage Ui250 VThermal test current Ithe10 A

Utilisation category AC-15: 230 V / 4 A

DC-13: 24 V / 4 A

Max. fuse rating 6 A gG D-fuse

#### **ATEX**

Explosion protection categories for gases

None
Explosion protected category for dusts


None

## **Dimensions**

Dimensions of the sensor

- Width of sensor- Height of sensor- Length of sensor30

#### notice




This type termination (IDC) method enables simple connetion of flexible conductors without the need for the use of conductor ferrules

## Included in delivery

Actuators must be ordered separately.

Slot sealing plugs

## **Diagram**




Note Diagram


positive break NC contact



no active



# Switch travel diagram



Notes Switch travel diagram

Contact closed

☐Contact open

Setting range

(L) Break point

Positive opening sequence/- angle

VS adjustable range of NO contact

VÖ adjustable range of NC contact

N after travel

### **Documents**

Operating instructions and Declaration of conformity (pl) 526 kB, 24.09.2018

Code: mrl\_az17\_pl

Operating instructions and Declaration of conformity (ro) 511 kB, 25.01.2012

Code: mrl\_az17\_ro

Operating instructions and Declaration of conformity (sv) 491 kB, 07.08.2015

Code: mrl\_az17\_sv

Operating instructions and Declaration of conformity (jp) 749 kB, 24.09.2018

Code: mrl\_az17\_jp

Operating instructions and Declaration of conformity (it) 494 kB, 24.09.2018

Code: mrl\_az17\_it

Operating instructions and Declaration of conformity (da) 510 kB, 25.01.2012

Code: mrl\_az17\_da

Operating instructions and Declaration of conformity (br) 381 kB, 18.12.2018

Code: ace\_mrl\_az17\_br

Operating instructions and Declaration of conformity (es) 496 kB, 24.09.2018

Code: mrl\_az17\_es

Operating instructions and Declaration of conformity (de) 486 kB, 05.04.2018

Code: mrl\_az17\_de

Operating instructions and Declaration of conformity (en) 495 kB, 24.09.2018

Code: mrl\_az17\_en

Operating instructions and Declaration of conformity (fr) 525 kB, 24.09.2018

Code: mrl\_az17\_fr

Operating instructions and Declaration of conformity (nl) 496 kB, 24.09.2018

Code: mrl\_az17\_nl

Operating instructions and Declaration of conformity (pt) 498 kB, 24.09.2018

Code: mrl\_az17\_pt

Operating instructions and Declaration of conformity (cs) 551 kB, 24.09.2018

Code: mrl\_az17\_cs

BG-test certificate (en) 159 kB, 26.11.2015

Code: z\_z17p02

BG-test certificate (de) 181 kB, 26.11.2015

Code: z\_z17p01

CCC certification (cn) 3 MB, 18.10.2017

Code: q\_175p03


CCC certification (en) 3 MB, 29.08.2017

Code: q\_175p02

EAC certification (ru) 844 kB, 05.10.2015

Code: q\_6037p17\_ru

**Images** 



Dimensional drawing (basic component)

K.A. Schmersal GmbH & Co. KG, Möddinghofe 30, D-42279 Wuppertal The data and values have been checked throroughly. Technical modifications and errors excepted. Generiert am 13.02.2019 - 14:36:57h Kasbase 3.3.0.F.64l