13.02.2019

14:24:05h

# Datasheet - BNS 260-11ZG-ST-L

Safety sensors / BNS 260

≥ Preferred typ



(Minor differences between the printed image and the original product may exist!)

#### **Ordering details**

Product type description Article number EAN Code eCl@ss

BNS 260-11ZG-ST-L 101184383 4030661321837 27-27-24-02

ΒG

EAC

USA/CAN



# Standards

Approval


Approval

B10d Normally-closed contact/Normally open contact (NC/NO)

- notice

Mission time

notice



t <sub>ovele</sub>

#### **Global Properties**

# 🕱 SCHMERSAL

- Thermoplastic enclosure
- · Small body
- · Concealed mounting possible
- 26 mm x 36 mm x 13 mm
- Long life
- no mechanical wear
- Insensitive to transverse misalignment
- · Insensitive to soiling
- Connector M8 x 1, 4-pole

| Standards                                       | IEC 60947-5-3, BG-GS-ET-14                    |  |
|---|---|--|
| Compliance with the Directives (Y/N) CE         | Yes   |  |
| Materials                                       |   |  |
| - Material of the housings                      | Plastic, glass-fibre reinforced thermoplastic |  |
| Weight  | 18  |  |
| Coding available (Y/N)                          | Yes   |  |
| Monitoring function of downstream devices (Y/N) | No  |  |
| Prerequisite evaluation unit                    |   |  |
| Recommended safety-monitoring module            |   |  |
| Recommended actuator                            | BPS 260                                       |  |
|   |   |  |

# Mechanical data

| Design of electrical connection    | Connector M8   |
|------------------------------------|--|
| mechanical installation conditions | quasi-flush  |
| Active area                        |  |
| Ensured switch distance ON Sao     | 5 mm   |
| Ensured switch distance OFF Sar    | 15 mm  |
| notice                             | Axial misalignment<br>The safety sensor and the actuator tolerate a horizontal and vertical<br>misalignment to each other. The possible misalignment depends on the<br>distance of the active surfaces of the sensor and the actuator. The sensor<br>is active in the tolerance range. |
| Type of actuation                  | Magnet   |
| Direction of motion                | head-on with regard to the active surface  |
| restistance to shock               | 30 g / 11 ms   |
| Resistance to vibration            | 10 55 HZ, Amplitude 1 mm   |
| Door hinge                         | left   |
|                                    |  |

# **Ambient conditions**

| −25 °C |
|--------|
| +70 °C |
|        |
| −25 °C |
| +70 °C |
| IP67   |
|        |

# **Electrical data**

| Integrated Safety monitoring module available (Y/N)    | No          |
|--|-------------|
| Cross circuit/short circuit recognition possible (Y/N) | Yes         |
| Voltage type   | VDC         |
| Switch frequency                                       | max. 5 HZ   |
| Switching voltage                                      | max. 24 VDC |
| Switching current                                      | max. 10 mA  |
| Switching capacity                                     | max. 240 mW |
|  |             |

# Outputs

| Design of control output                 |   |  |
|--|---|--|
| Number of shutters                       | 1 |  |
| Number of openers                        | 1 |  |
| Design of output signal switching device |   |  |

## **Electrical data - Safety outputs**

| Number of secure semi-conductor outputs                               | 0     |
|---|-------|
| Number of secure outputs with contact                                 | 2     |
| Electrical data - Diagnostic output                                   |       |
| Number of semi-conductor outputs with signaling function              | 0     |
| Number of outputs with signaling function that already have a contact | 0     |
| LED switching conditions display                                      |       |
| LED switching conditions display (Y/N)                                | Yes   |
| - The LED is illuminated when the guard is closed.                    |       |
| ATEX  |       |
| Explosion protection categories for gases                             | None  |
| Explosion protected category for dusts                                | None  |
| Dimensions  |       |
| Dimensions of the sensor  |       |
| - Width of sensor   | 26 mm |
|   | 36 mm |
| - Height of sensor  | 30 mm |

#### notice

Contact symbols shown for the closed condition of the guard device. The contact configuration for versions with or without LED is identical. The number in brackets indicate the PIN number of the connector. Contact S21-S22; S13-S14 must be integrated in the safety circuit

#### **Included in delivery**

Actuators must be ordered separately.

#### **Indication legend**

Switch on/off diagram The actuating graph also applies to the BPS 260-2, the actuator with 90° inverted actuation.

## Diagram

(3) BK S13 → S14 BU (4) (1) WH S21 → S22 BN (2)

Note Diagram → positive break NC contact ① active

#### Ordering code

BNS 260-(1)(2)Z(3)-(4)-(5)

| (1)     |  |
|---------|--|
| 11      | 1 Normally open contact (NO) / 1 Opener (NC) |
| 02      | 2 Opener (NC)                                |
| (2)     |  |
| without | without Diagnostic output                    |
| /01     | 1 Opener (NC)                                |
| (3)     |  |
| without | without LED switching conditions display     |
| G       | with LED switching conditions display        |
| (4)     |  |
| without | Pre-wired cable                              |
| ST      | with connector                               |
| (5)     |  |
| L       | Door hinge on left-hand side                 |
| R       | Door hinge on right-hand side                |
|         |  |

#### **Documents**

**Operating instructions and Declaration of conformity** (pt) 331 kB, 24.10.2018 Code: mrl\_bns260\_pt

**Operating instructions and Declaration of conformity** (cs) 365 kB, 25.10.2018 Code: mrl\_bns260\_cs

**Operating instructions and Declaration of conformity** (fr) 331 kB, 24.10.2018 Code: mrl\_bns260\_fr

**Operating instructions and Declaration of conformity** (de) 290 kB, 01.10.2018 Code: mrl\_bns260\_de

**Operating instructions and Declaration of conformity** (it) 321 kB, 24.10.2018 Code: mrl\_bns260\_it

**Operating instructions and Declaration of conformity** (nl) 329 kB, 23.10.2018 Code: mrl\_bns260\_nl

**Operating instructions and Declaration of conformity** (pl) 365 kB, 25.10.2018 Code: mrl\_bns260\_pl

**Operating instructions and Declaration of conformity** (sv) 442 kB, 25.10.2018 Code: mrl\_bns260\_sv

**Operating instructions and Declaration of conformity** (jp) 398 kB, 24.09.2018 Code: mrl\_bns260\_jp

Operating instructions and Declaration of conformity (en) 330 kB, 01.10.2018


Code: mrl\_bns260\_en

**Operating instructions and Declaration of conformity** (es) 329 kB, 24.10.2018 Code: mrl\_bns260\_es


**Operating instructions and Declaration of conformity** (da) 343 kB, 25.10.2018 Code: mrl\_bns260\_da

**EAC certification** (ru) 782 kB, 05.10.2015 Code: q\_6044p17\_ru


### Images




#### Dimensional drawing (basic component)




Characteristic curve





#### Contact arrangement



## System components

#### Actuator



#### 101184395 - BPS 260-1

· Actuator and sensor on a mounting level



#### 101184396 - BPS 260-2

Actuator 90 ° attached to the sensor

#### Accessories



#### 101184643 - SPACER BNS 260

to mount the magnetic safety sensor and actuator on ferromagnetic material

#### Connector



#### 101194059 - BNS-Y-11

• enables the interconnection and the connection of BNS safety sensors to a common safety monitoring module

• for BNS 33, BNS 36, BNS 260 (with 1 NC/1 NO)

The data and values have been checked throroughly. Technical modifications and errors excepted. Generiert am 13.02.2019 - 14:24:06h Kasbase 3.3.0.F.64I