13.02.2019

14:32:08h

# Datasheet - T1V10S 500L-22Z

Safety switch for hinged guards / Hinge safety switch / T.V10S 500





- Metal enclosure
- Good resistance to oil and petroleum spirit
- $\bullet$  Actuator shaft can be turned 360°
- 110 mm x 110 mm x 84 mm
- 3-channel, alternating monitoring
- 2 Cable entry M 20 x 1.5

(Minor differences between the printed image and the original product may exist!)

### **Ordering details**

Product type description Article number EAN Code eCl@ss

#### Approval

Approval

# **((()** ccc

T1V10S 500L-22Z

4030661055459

101131112

27-27-26-01

### Classification

Standards	
B10d Normally-closed contact (NC)	
Mission time	
notice	

EN ISO 13849-1 20.000.000 20 Years

 $MTTF_{d} = \frac{B_{100}}{0.1 \times n_{op}}$ 

 $n_{op} = \frac{d_{op} x h_{op} x 3600 \text{ s/h}}{t_{oycle}}$ 

#### **Global Properties**

Permanent light Standards Materials - Material of the housings - Material of the contacts Housing coating Weight

# Mechanical data

# T.V10S 500 EN 60947-5-1, BG-GS-ET-15

Aluminium Silver painted 665

Design of electrical connection	Screw connection
Cable entry M 20 x 1.5	2
Cable section	
- Min. Cable section	
- Max. Cable section	1 x 1.5 mm²
Design of actuating element	Other
Mechanical life	3.000.000 operations
Switching frequency	max. 1000 /h
notice	All indications about the cable section are including the conductor ferrules.
Shaft bore	Ø 10
Positive break angle	14 °
Positive break torque	15 Ncm
socket (Y/N)	Yes
Universal joint (Y/N)	No

# **Ambient conditions**

Ambient temperature	
- Min. environmental temperature	−25 °C
- Max. environmental temperature	+80 °C
Protection class	IP67

## **Electrical data**

Design of control element	Normally open contact (NO), Opener (NC)
Design of control element	Normally open contact (NO), Opener (NC)
Switching principle	Creep circuit element
Number of auxiliary contacts	3
Number of safety contacts	1
Rated impulse withstand voltage Uimp	4 kV
Rated insulation voltage Ui	250 V
Thermal test current Ithe	6 A
Utilisation category	AC-15: 230 V / 4 A,
	DC-13: 24 V / 1 A
Max. fuse rating	6 A gG D-fuse

# ATEX

Explosion protection categories for gases	None
Explosion protected category for dusts	None


## Dimensions

- Width of sensor

- Height of sensor
- Length of sensor

110 mm 110 mm 84 mm

## Diagram



Note Diagram → positive break NC contact active no active Normally-open contact Normally-closed contact

#### **Ordering code**

#### T(1)V10S 500L-(2)Z

(1)	
without	with universal joint
1	with socket
(2)	
22	2 Normally open contact (NO) / 2 Opener (NC)
33	3 Normally open contact (NO) / 3 Opener (NC)

#### Documents

**Operating instructions and Declaration of conformity** (da) 243 kB, 18.06.2013 Code: mrl\_tv10s500\_da

**Operating instructions and Declaration of conformity** (es) 281 kB, 21.12.2017 Code: mrl\_tv10s500\_es

**Operating instructions and Declaration of conformity** (pt) 282 kB, 31.01.2018 Code: mrl\_tv10s500\_pt

**Operating instructions and Declaration of conformity** (fr) 285 kB, 28.11.2017 Code: mrl\_tv10s500\_fr

**Operating instructions and Declaration of conformity** (nl) 281 kB, 13.08.2018 Code: mrl\_tv10s500\_nl

Operating instructions and Declaration of conformity (jp) 993 kB, 22.09.2011

#### Code: mrl\_tv10s500\_jp

**Operating instructions and Declaration of conformity** (de) 263 kB, 14.11.2017 Code: mrl\_tv10s500\_de

**Operating instructions and Declaration of conformity** (pl) 309 kB, 23.03.2018 Code: mrl\_tv10s500\_pl

**Operating instructions and Declaration of conformity** (it) 281 kB, 28.11.2017 Code: mrl\_tv10s500\_it

**Operating instructions and Declaration of conformity** (en) 283 kB, 14.11.2017 Code: mrl\_tv10s500\_en


**CCC certification** (en) 577 kB, 12.12.2006 Code: q\_349p02

CCC certification (cn) 609 kB, 12.12.2006 Code: q\_349p03

#### Images



Product photo



Dimensional drawing (basic component)

K.A. Schmersal GmbH & Co. KG, Möddinghofe 30, D-42279 Wuppertal The data and values have been checked throroughly. Technical modifications and errors excepted. Generiert am 13.02.2019 - 14:32:08h Kasbase 3.3.0.F.64l