

Datasheet - EL



Command and signalling devices / Contact and light terminal blocks (EF/EL) System / Light terminal blocks (as voltage supply) with Ba9S holder / Light terminal block EL



- Print with incandescent lamp symbol

(Minor differences between the printed image and the original product may exist!)

Ordering details


Product type description	EL
Article number	101006553
EAN Code	4250116201068
eCl@ss	27-37-13-02

Approval

Approval



Global Properties

Permanent light	Leuchtelement EL
Standards	IEC/EN 60947-1, EN 60947-5-1
Compliance with the Directives (Y/N) 	No
Terminal designations	X1-X2
Mounting position	arbitrarily
Materials	
- Material of the housings	Plastic, glass-fibre reinforced thermoplastic self-extinguishing
Weight	20

Mechanical data

Connection type	Screw connection
Cable section	
- Min. Cable section	0,5, rigid 0,5, flexible
- Max. Cable section	2,5, rigid 1,5, flexible
Mounting flange position	3
mounting	pluggable
terminals	Protection against polarity reversal
Tightening torque for fixing screws	max. 1 Nm

Ambient conditions

Ambient temperature

- | | |
|----------------------------------|-----|
| - Min. environmental temperature | -25 |
| - Max. environmental temperature | +80 |

Protection class

- | | |
|------------------------------|------|
| - Protection class-Terminals | IP20 |
|------------------------------|------|

Electrical data

Rated insulation voltage U_i	440 V
--------------------------------	-------

Rated operating voltage U_e	250 V
-------------------------------	-------

LED switching conditions display

With integrated LED (Y/N)	No
---------------------------	----

LED switching conditions display

- | | |
|------------------------|-----------|
| - Supply voltage U_B | 24 VAC/DC |
| - colour of the LED | without |

Dimensions

Dimensions

- | | |
|----------|-------|
| - Width | 10 mm |
| - Depth | 60 mm |
| - Length | 46 mm |

Documents

CCC certification (en) 1 MB, 20.06.2017

Code: q_efelp02

CCC certification (cn) 1 MB, 20.06.2017

Code: q_efelp03

EAC certification (ru) 779 kB, 05.10.2015

Code: q_6043p17_ru

K.A. Schmersal GmbH & Co. KG, Möddinghofe 30, D-42279 Wuppertal

The data and values have been checked thoroughly. Technical modifications and errors excepted.

Generiert am 13.02.2019 - 12:47:23h Kasbase 3.3.0.F.64I